

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0574-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HLA01CT001 Range 0 ~ 100
 Instrument Description FORCED DRAFT FAN A INLET AIR Unit °C
 TEMPERATURE 1
 Manufacture YAMARI Out. Signal 4 - 20 mA
 Model - Max. Deviation 1.7 °C (JIS)
 Serial Number 5901368 Cal. Date 12-05-2024
 Instrument Location BOILER / FDFAN B 2ND FLOOR Temp. Element Thermocouple Type E

Environment Condition

Temperature 29.5 °C
 Humidity 65 % RH

Calibration Result

As Found					Data Reading					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.980	40.000	0.020	Pass										
45	45.030	44.900	-0.130	Pass										
50	50.030	49.900	-0.130	Pass										
75	75.010	75.000	-0.010	Pass										
100	100.030	100.000	-0.030	Pass										

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 13-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



INDONESIA
 M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

