

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0576-24-HI-CAL-10D

Customer Information

Company Name : PT. Bhumi Jati Power
 Address : PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. : C-BJP-24-0013-OTH

Instrument Information

KKS No. : 60HLA01CT003 Range : 0 – 100
 Instrument Description : FORCED DRAFT FAN A INLET AIR Unit : °C
 TEMPERATURE 3
 Manufacture : YAMARI Out. Signal : 4 - 20 mA
 Model : - Max. Deviation : 1.7 °C (JIS)
 Serial Number : 5901370 Cal. Date : 12-05-2024
 Instrument Location : BOILER / FDFAN B 2ND FLOOR Temp. Element : Thermocouple Type E

Environment Condition

Temperature : 29.7 °C
 Humidity : 63 % RH

Calibration Result

As Found					Data Reading					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.980	40.100	0.120	Pass										
45	45.010	44.900	-0.110	Pass										
50	50.010	49.900	-0.110	Pass										
75	74.960	74.900	-0.060	Pass										
100	100.050	100.100	0.050	Pass										

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 13-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiqul Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

