

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0703-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60HLA02CT001

Instrument Description

FORCED DRAFT FAN A OUTLET AIR TEMPERATURE

Manufacture

YAMARI

Model / Serial Number

- / 5901571

Instrument Location

BOILER GROUND FLOOR

Range

0 - 100

Unit

°C

Out. Signal

4 - 20 mA

Max. Deviation

1.7 °C (JIS)

Cal. Date

17-06-2026

Temp. Element

Thermocouple Type E

Environment Condition

Temperature

31.4 °C

Humidity

57 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	40.000	0.400	Pass					
45	44.600	44.800	0.200	Pass					
50	49.500	49.900	0.400	Pass					
75	74.900	75.200	0.300	Pass					
100	99.900	100.500	0.600	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

DOCUMENTING PROCESS

CALIBRATOR FLUKE 754

DRY WELL CALIBRATOR ADDITEL
875

Serial Number

3611011

Certificate Number

MAL 26031229

Calibration Date

06-03-2026

S-25010822

22-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 19-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

