

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0265-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLA11CP002	Range	-100 ~ 150
Instrument Description	FORCED DRAFT FAN B INLET AIR PRESSURE 2	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501758	Cal. Date	14-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature: 28.1 °C
 Humidity: 51 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100.0	4.000	3.998	-0.002	-0.012	Pass						
-37.5	8.000	8.000	0.000	0.000	Pass						
25.0	12.000	12.001	0.001	0.006	Pass						
87.5	16.000	16.001	0.001	0.006	Pass						
150.0	20.000	19.998	-0.002	-0.012	Pass						
150.0	20.000	19.998	-0.002	-0.012	Pass						
87.5	16.000	16.001	0.001	0.006	Pass						
25.0	12.000	11.999	-0.001	-0.006	Pass						
-37.5	8.000	7.996	-0.004	-0.025	Pass						
-100.0	4.000	3.999	-0.001	-0.006	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 15-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signature,



M. Taufiq Nur Fitriyan

Calibrated by,



Faihsol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person