

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0266-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLA11CP003	Range	-100 ~ 150
Instrument Description	FORCED DRAFT FAN B INLET AIR PRESSURE 3	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501759	Cal. Date	14-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature 28.2 °C
 Humidity 52 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100.0	4.006	3.992	-0.014	-0.088	Pass						
-37.5	8.006	7.992	-0.014	-0.088	Pass						
25.0	12.000	11.985	-0.015	-0.094	Pass						
87.5	16.000	15.991	-0.009	-0.056	Pass						
150.0	20.000	19.986	-0.014	-0.087	Pass						
150.0	20.000	19.986	-0.014	-0.087	Pass						
87.5	16.000	15.986	-0.014	-0.087	Pass						
25.0	12.000	11.990	-0.010	-0.062	Pass						
-37.5	8.000	7.984	-0.016	-0.100	Pass						
-100.0	4.000	3.984	-0.016	-0.100	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 15-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Yaufig Nur Fitriyan

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person