

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0577-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLA11CT001	Range	0 ~ 100
Instrument Description	FORCED DRAFT FAN B INLET AIR TEMPERATURE 1	Unit	°C
Manufacture	YAMARI	Out. Signal	4-20 mA
Model	-	Max. Deviation	1.7 °C (JIS)
Serial Number	451663	Cal. Date	12-05-2024
Instrument Location	BOILER / FD FAN 2ND FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 34.3 °C
 Humidity 58 % RH

Calibration Result

As Found					Data Reading					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.300	0.300	Pass										
45	45.000	45.200	0.200	Pass										
50	50.000	50.100	0.100	Pass										
75	75.000	75.000	0.000	Pass										
100	100.000	99.900	-0.100	Pass										

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 13-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taqibul Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

