

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0462-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLA51CP001	Range	-100 ~ 100
Instrument Description	WINDBOX AIR PRESSURE (D)	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V5017225	Cal. Date	20-05-2024
Instrument Location	BOILER 5TH FLOOR		

Environment Condition

Temperature: 27.2 °C
Humidity: 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100	4.000	3.994	-0.006	-0.037	Pass						
-50	8.000	7.993	-0.007	-0.044	Pass						
0	12.000	11.995	-0.005	-0.031	Pass						
50	16.000	15.995	-0.005	-0.031	Pass						
100	20.000	19.993	-0.007	-0.044	Pass						
100	20.000	19.993	-0.007	-0.044	Pass						
50	16.000	15.995	-0.005	-0.031	Pass						
0	12.000	11.992	-0.008	-0.050	Pass						
-50	8.000	7.991	-0.009	-0.056	Pass						
-100	4.000	3.994	-0.006	-0.037	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 031	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Laboratory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Falstol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

