

## REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 1180-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HLA53AA201 Sensitivity 0.5 %  
Instrument Description WB INLET AIR DAMPER(FRONT LOWER RIGHT SIDE) Damping Time 1 s  
Manufacture IMI CCI Actuator Action ATO  
Model DU-60GHP Inspection Date 20-05-2024  
Serial Number A24344JP-24B  
Instrument Location BOILER 5TH FLOOR

### Environment Condition

Temperature 31 °C Humidity 43 % RH

### Traveling Time

Open to Close 14.45 s Close to Open 14.78 s

### Stroke Result

Test Point	As Found			
	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.5	4.120	0.6	0
25	25.0	8.050	25.3	45
50	50.0	12.060	50.2	90
75	75.0	16.040	75.2	135
100	99.8	20.060	100	180

Test Point	As Left			
	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Air Regulator Check  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
LB02 PROCESS CALIBRATOR	SS18-0015	S.22 012 540	07-10-2022
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page

Date of issue, 21-05-2024

Customer Signature,




Ayrtun Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Indonesiyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

