

## REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 1181-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HLA55AA201 Sensitivity 0.3 %  
Instrument Description WB INLET AIR DAMPER(FRONT MIDDLE LEFT SIDE) Damping Time 1 s  
Manufacture IMI CCI Actuator Action ATO  
Model DU-60GHP Inspection Date 20-05-2024  
Serial Number A24344JP-24O  
Instrument Location BOILER 3.5TH FLOOR

### Environment Condition

Temperature 32 °C Humidity 44 % RH

### Traveling Time

Open to Close 12.38 s Close to Open 15.91 s

### Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.6	3.910	0.0	0
25	24.5	7.930	24.6	45
50	49.8	11.990	50.1	90
75	74.4	15.990	74.9	135
100	100.1	20.000	10.0	180

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Air Regulator Check  OK  Not OK

### Remark

### Test Equipment


Description	Serial Number	Certificate Number	Calibration Date
LB02 PROCESS CALIBRATOR	SS18-0015	S.22 012 540	07-10-2022
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,




Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Tahiro Nur Fitriyan  
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

