

REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 1182-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HLA57AA201	Sensitivity	0.3 %
Instrument Description	WB INLET AIR DAMPER(FRONT MIDDLE RIGHT SIDE)	Damping Time	1 s
Manufacture	IMI CCI	Actuator Action	ATC
Model	DV-600HP	Inspection Date	20-05-2024
Serial Number	A24344JP-24D		
Instrument Location	BOILER 4TH FLOOR		

Environment Condition

Temperature 31 °C Humidity 43 % RH

Traveling Time

Open to Close 16.60 s Close to Open 13.95 s

Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.1	3.940	0.0	0
25	24.6	7.940	24.8	45
50	49.8	11.970	49.7	90
75	74.7	15.980	74.6	135
100	100.1	20.000	100.0	180

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]

Visual Inspection

Leak Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Tightness Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Corrosion Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Accessories Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Air Regulator Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK					

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 21-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved by,



M. Taufiq Nur Filnyan
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

