

REPORT OF INSPECTION

ON-OFF VALVE

Certificate No. : 1183-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HLA58AA201 Damping Time 0.1 s
Instrument Description SIDE STREAM AIRPORT FRONT INLET AIR FLOW Inspection Date 21-05-2024
CONTROL DAMPER (RIGHT SIDE) OPEN
Manufacture KONAMI
Model
Serial Number CP66-J524175
Instrument Location BOILER 3RD FLOOR

Environment Condition

Temperature 30 °C Traveling Time
Humidity 42 % RH Open to Close 00.56 s
Close to Open 00.60 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Air Regulator Check OK Not OK

Remark

Test Equipment


Description Serial Number Certificate Number Calibration Date
STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 22-05-2024


Customer Signature,


Ayrtan Humardani Putradhi

Approved Signatory,


M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,


Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

