

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0303-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HLA59CP001
Instrument Description WINDBOX AIR PRESSURE (E)
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V501721
Instrument Location BOILER 6TH FLOOR

Range -100 ~ 100
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 28-05-2026

Environment Condition

Temperature 31 °C Humidity 72 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-100.000	4.000	3.997	-0.003	-0.019	Pass						
-50.000	8.000	7.992	-0.008	-0.050	Pass						
0.000	12.000	11.996	-0.004	-0.025	Pass						
50.000	16.000	15.997	-0.003	-0.019	Pass						
100.000	20.000	20.000	0.000	0.000	Pass						
50.000	16.000	16.001	0.001	0.006	Pass						
0.000	12.000	12.002	0.002	0.013	Pass						
-50.000	8.000	8.000	0.000	0.000	Pass						
-100.000	4.000	3.997	-0.003	-0.019	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 03-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

HERVITAMA

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

