

REPORT OF INSPECTION CONTROL VALVE Certificate No. : 1188-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HLA65AA201	Sensitivity	1 %
Instrument Description	WB INLET AIR DAMPER(REAR LOWER RIGHT SIDE)	Damping Time	0.5 s
Manufacture	IMI CCI SMART POSITIONER	Actuator Action	ATC
Model	DU-60GHP	Inspection Date	21-05-2024
Serial Number	A24344JP-24M		
Instrument Location	BOILER 3RD FLOOR		

Environment Condition

Temperature 30 °C Humidity 41 % RH

Traveling Time

Open to Close 13.13 s Close to Open 15.08 s

Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.0	4.020	0.0	0
25	25.1	8.050	25.2	45
50	50.1	12.050	50.2	90
75	75.1	16.040	75.1	135
100	99.6	19.950	99.7	180

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]

Visual Inspection

Leak Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Tightness Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Corrosion Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Accessories Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Air Regulator Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK					

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022
LB02 PROCESS CALIBRATOR	SS18-0015	S.22 012 540	07-10-2022

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 22-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person