

REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 1191-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HLA69AA201 Sensitivity 1 %
Instrument Description WB INLET AIR DAMPER(REAR MIDDLE RIGHT SIDE) Damping Time 0.5 s
Manufacture IMI CCI SMART POSITIONER Actuator Action ATC
Model DU-60GHP Inspection Date 21-05-2024
Serial Number A24344JP-24K
Instrument Location TURBINE 3.5 FLOOR

Environment Condition

Temperature 30 °C Humidity 41 % RH

Traveling Time

Open to Close 14.69 s Close to Open 15.35 s

Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.0	3.980	0.0	0
25	25.3	8.910	25.0	45
50	50.5	12.010	49.9	90
75	75.4	16.000	75.0	135
100	100.1	19.950	99.7	180

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Air Regulator Check OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022
LB02 PROCESS CALIBRATOR	SS18-0015	S.22 012 540	07-10-2022

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 22-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Indro Nur Firriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

