REPORT OF INSPECTION
CONTROL VALVE

Certificate No. : 1193-24-HI-CAL-10J

Customer Information

Company Name	PT. Bhumi Jati Power
Address	PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.	C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HLA71AA201	Sensitivity	1 %
Instrument Description	WB INLET AIR DAMPER(REAR UPPER LEFT SIDE)	Damping Time	0.5 s
Manufacture	IMI CCI SMART POSITIONER	Actuator Action	ATC
Model	DU-60GHP	Inspection Date	21-05-2024
Serial Number	A24344JP-24L		
Instrument Location	BOILER 3.5TH FLOOR		

Environment Condition

Temperature 31 °C Humidity 44 % RH

Traveling Time

Open to Close 17.03 s Close to Open 15.22 s

Stroke Result

As Found				
Test Point	Local	Feadback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.1	4.000	0.0	0
25	25.5	8.090	25.6	45
50	50.5	12.110	50.5	90
75	75.5	16.100	75.5	135
100	100.3	20.030	100.0	180

As Left				
Test Point	Local	Feadback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]

Visual Inspection

Leak Check	✓	OK		Not OK	Tighteness Check	✓	OK		Not OK
Corrosion Condition	✓	OK		Not OK	Accessories Check	✓	OK		Not OK
Air Regulator Check	✓	OK		Not OK					

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022
LB02 PROCESS CALIBRATOR	SS18-0015	S.22 012 540	07-10-2022

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 22-05-2024

Customer Signature,	Approved Signatory,	Calibrated by,
Ayrton Humardani Putradhi	M. Taufiqur Rohman	Daday Daryatun

HERVITAMA INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*
This certificate is valid if it has approved and signed by authorized person