

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0308-26-HI-CAL-10

Customer Information

Company Name
Address
Contract No.PT. Bhumi Jati Power
PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
C-BJP-26-0004-OTH

Instrument Information

KKS No.
Instrument Description
Manufacture
Model / Serial Number
Instrument Location60HLA75CF002
NO PORT FRONT LEFT INLET AIR FLOW 2
YOKOGAWA
EJX110A / 91V501662
BOILER 6TH FLOORRange 0 ~ 31
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 29-05-2026

Environment Condition

Temperature 25 °C Humidity 56 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	4.000	0.000	0.000	Pass						
7.800	8.026	8.025	-0.001	-0.006	Pass						
15.500	12.000	12.002	0.002	0.013	Pass						
23.300	16.026	16.025	-0.001	-0.006	Pass						
31.000	20.000	20.001	0.001	0.006	Pass						
23.300	16.026	16.027	0.001	0.006	Pass						
15.500	12.000	12.000	0.000	0.000	Pass						
7.800	8.026	8.026	0.000	0.000	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential TransmitterThis certificate comprises 2 pages
Date of issue, 03-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

