

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0447-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLA77CF001	Range	0 ~ 31
Instrument Description	NO PORT FRONT RIGHT INLET AIR FLOW 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501666	Cal. Date	15-05-2024
Instrument Location	BOILER 6TH FLOOR		

Environment Condition

Temperature 25.9 °C
Humidity 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.00	4.000	3.873	-0.127	-0.794	Fail	0.00	4.000	4.003	0.003	0.019	Pass
7.75	8.000	7.943	-0.057	-0.356	Pass	7.75	8.000	8.004	0.004	0.025	Pass
15.50	12.005	11.900	-0.105	-0.656	Fail	15.50	12.000	12.006	0.006	0.038	Pass
23.35	16.005	15.877	-0.128	-0.800	Fail	23.35	16.000	16.003	0.003	0.019	Pass
31.00	20.005	19.838	-0.167	-1.044	Fail	31.00	20.000	20.011	0.011	0.069	Pass
31.00	20.005	19.838	-0.167	-1.044	Fail	31.00	20.000	20.011	0.011	0.069	Pass
23.25	16.000	15.861	-0.139	-0.869	Fail	23.25	16.000	16.001	0.001	0.006	Pass
15.50	12.000	11.877	-0.123	-0.769	Fail	15.50	12.000	12.010	0.010	0.062	Pass
7.75	8.000	7.904	-0.096	-0.600	Fail	7.75	8.000	8.007	0.007	0.044	Pass
0.00	4.000	3.944	-0.056	-0.350	Pass	0.00	4.000	3.994	-0.006	-0.037	Pass

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	S. 23 014 463	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

Customer Signature,




Ayrtan Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Erishol Anwar

This certificate comprise of 1 page
Date of issue, 16-05-2024

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

