

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0453-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HLA79CF001	Range	0 – 31
Instrument Description	NO PORT REAR LEFT INLET AIR FLOW 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501665	Cal. Date	15-05-2024
Instrument Location	BOILER 6TH FLOOR		

### Environment Condition

Temperature: 27.6 °C  
Humidity: 52 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.00	4.000	4.001	0.001	0.006	Pass						
7.75	8.000	7.990	-0.010	-0.062	Pass						
15.50	12.000	11.985	-0.015	-0.094	Pass						
23.35	16.005	15.972	-0.033	-0.206	Pass						
31.00	20.000	19.999	-0.001	-0.006	Pass						
31.00	20.000	19.999	-0.001	-0.006	Pass						
23.25	15.995	15.996	0.001	0.006	Pass						
15.50	12.005	12.000	-0.005	-0.031	Pass						
7.75	8.000	8.013	0.013	0.081	Pass						
0.00	3.995	4.001	0.006	0.038	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	S. 23 014 463	09-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
Approved Signature,



M. Taufiq Nur Fitriyan  
INDONESIA

This certificate comprise of 1 page  
Date of issue, 16-05-2024

Calibrated by,



Paishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

