

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0456-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HLA79CP001 Range -100 ~ 100
 Instrument Description NO PORT AIR PRESSURE (REAR LEFT) Unit mbarg
 Manufacture YOKOGAWA Out. Signal 4 - 20 mA
 Model EJX110A Max. Error 0.5 %
 Serial Number 91V501719 Cal. Date 15-05-2024
 Instrument Location BOILER 6TH FLOOR

Environment Condition

Temperature 27.5 °C
 Humidity 52 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100	4.000	3.997	-0.003	-0.019	Pass						
-50	8.000	7.999	-0.001	-0.006	Pass						
0	12.000	11.997	-0.003	-0.019	Pass						
50	16.000	16.002	0.002	0.012	Pass						
100	20.000	20.008	0.008	0.050	Pass						
100	20.000	20.008	0.008	0.050	Pass						
50	16.000	16.005	0.005	0.031	Pass						
0	12.000	11.998	-0.002	-0.013	Pass						
-50	8.000	8.004	0.004	0.025	Pass						
-100	4.000	3.998	-0.002	-0.012	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Authorized by,



M. Nauri Nur Fitriyan
 INDONESIA

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person