

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0457-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLA81CP001	Range	-100 ~ 100
Instrument Description	NO PORT AIR PRESSURE (REAR RIGHT)	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501720	Cal. Date	15-05-2024
Instrument Location	BOILER 6TH FLOOR		

Environment Condition

Temperature: 27.6 °C
 Humidity: 51 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100	4.000	3.996	-0.004	-0.025	Pass						
-50	8.000	7.993	-0.007	-0.044	Pass						
0	12.000	12.001	0.001	0.006	Pass						
50	16.000	15.998	-0.002	-0.013	Pass						
100	20.000	19.993	-0.007	-0.044	Pass						
100	20.000	19.993	-0.007	-0.044	Pass						
50	16.000	15.994	-0.006	-0.038	Pass						
0	12.000	12.002	0.002	0.013	Pass						
-50	8.000	7.992	-0.008	-0.050	Pass						
-100	4.000	3.993	-0.007	-0.044	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

HERVITAMA
 Approved Signatory,



M. Fauzan Furqan
 INDONESIA

Calibrated by,



Faizol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person