

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0268-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLB01CF001	Range	0 – 63.8
Instrument Description	FORCED DRAFT FAN A SUCTION AIR FLOW 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501667	Cal. Date	28-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature: 27.2 °C
Humidity: 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.00	4.000	4.001	0.001	0.006	Pass						
15.95	8.000	7.978	-0.022	-0.137	Pass						
31.90	12.000	11.979	-0.021	-0.131	Pass						
47.85	16.000	15.985	-0.015	-0.094	Pass						
63.80	20.000	19.982	-0.018	-0.112	Pass						
63.80	20.000	19.982	-0.018	-0.112	Pass						
47.85	16.000	15.979	-0.021	-0.131	Pass						
31.90	12.000	11.979	-0.021	-0.131	Pass						
15.95	8.000	7.981	-0.019	-0.119	Pass						
0.00	4.000	4.002	0.002	0.013	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	s.21 014 749	23-12-2021

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

