

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0270-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HLB01CF003	Range	0 ~ 63.8
Instrument Description	FORCED DRAFT FAN A SUCTION AIR FLOW 3	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501669	Cal. Date	28-05-2024
Instrument Location	BOILER 2ND FLOOR		

### Environment Condition

Temperature: 27.1 °C  
Humidity: 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	4.003	0.003	0.019	Pass						
15.95	8.000	7.974	-0.026	-0.162	Pass						
31.90	12.000	11.983	-0.017	-0.106	Pass						
47.85	16.000	15.981	-0.019	-0.119	Pass						
63.80	20.000	19.980	-0.020	-0.125	Pass						
63.80	20.000	19.980	-0.020	-0.125	Pass						
47.85	16.000	15.981	-0.019	-0.119	Pass						
31.90	12.000	11.977	-0.023	-0.144	Pass						
15.95	8.000	7.988	-0.012	-0.075	Pass						
0.0	4.000	4.004	0.004	0.025	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	s.21 014 749	23-12-2021

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Alifudin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

