

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0328-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HLB11CF001 Range 0 ~ 63.8
Instrument Description FORCED DRAFT FAN B SUCTION AIR FLOW 1 Unit mbar
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX130A / 91V501673 Max. Error 0.5 %
Instrument Location BOILER 2ND FLOOR Cal. Date 31-05-2026

Environment Condition

Temperature 26 °C Humidity 55 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	4.002	0.002	0.013	Pass						
16.000	8.012	8.013	0.001	0.006	Pass						
31.900	12.000	12.003	0.003	0.019	Pass						
47.900	16.012	16.016	0.004	0.025	Pass						
63.800	20.000	20.006	0.006	0.038	Pass						
47.800	16.012	16.016	0.004	0.025	Pass						
31.900	12.000	12.002	0.002	0.013	Pass						
16.000	8.012	8.014	0.002	0.013	Pass						
0.000	4.000	4.002	0.002	0.013	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 04-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

