

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0274-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HLB11CP001	Range	0 ~ 100
Instrument Description	FORCED DRAFT FAN B CONTROL OIL PRESSURE 1	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501760	Cal. Date	18-05-2024
Instrument Location	BOILER FD FAN		

### Environment Condition

Temperature 31.7 °C  
Humidity 66 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
25.03	8.005	8.007	0.002	0.012	Pass						
50.06	12.009	12.009	0.000	0.000	Pass						
75.01	16.002	15.998	-0.004	-0.025	Pass						
100.04	20.006	20.007	0.001	0.006	Pass						
100.04	20.006	20.007	0.001	0.006	Pass						
75.01	16.002	16.007	0.005	0.031	Pass						
50.06	12.009	12.004	-0.005	-0.031	Pass						
25.03	8.005	8.006	0.001	0.006	Pass						
0.00	4.000	3.998	-0.002	-0.012	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 19-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Tanoesoeban

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person