

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0280-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HLD01CP014	Range	0 ~ 40
Instrument Description	HOT END STEAM PRESSURE TRANSMITTER	Unit	barg
Manufacture	ENDRESS HAUSER	Out. Signal	4 - 20 mA
Model	PMP51-AA21JB1SGBRKA1+F1JAPA	Max. Error	0.5 %
Serial Number	N808FB01129	Cal. Date	24-05-2024
Instrument Location	BOILER 2,5TH FLOOR		

Environment Condition

Temperature: 32.3 °C
 Humidity: 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	4.000	0.000	0.000	Pass						
10.004	8.002	8.001	-0.001	-0.006	Pass						
20.002	12.001	11.998	-0.003	-0.019	Pass						
30.006	16.002	15.994	-0.008	-0.050	Pass						
40.003	20.001	19.995	-0.006	-0.037	Pass						
40.003	20.001	19.995	-0.006	-0.037	Pass						
30.006	16.002	15.996	-0.006	-0.037	Pass						
20.002	12.001	11.997	-0.004	-0.025	Pass						
10.004	8.002	7.998	-0.004	-0.025	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	S. 23 014 463	09-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 25-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA
 Approved by,



M. Taufiq Nur Fitriyan
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person