

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0580-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HLD01CT036
 Instrument Description HOT END BEARING OIL TEMPERATURE TRANSMITTER
 Manufacture PR ELEKTRONIK
 Model 6335A
 Serial Number -
 Instrument Location BOILER 3RD FLOOR

Range 0 ~ 150
 Unit °C
 Out. Signal 4 - 20 mA
 Max. Deviation 1.7 °C (JIS)
 Cal. Date 15-05-2024
 Temp. Element Thermocouple Type E

Environment Condition

Temperature 31.6 °C
 Humidity 54 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.990	-0.010	Pass					
60	60.020	60.000	-0.020	Pass					
90	90.020	90.020	0.000	Pass					
120	119.980	120.200	0.220	Pass					
150	149.960	150.100	0.140	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Iqbal Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

