

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0731-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60HLD11CT037

Instrument Description

COLD END BEARING OIL TEMPERATURE TRANSMITTER

Manufacture

PR ELEKTRONIK

Model / Serial Number

6335A / -

Instrument Location

Boiler 2nd Floor

Range

0 ~ 150

Unit

°C

Out. Signal

4-20 mA

Max. Deviation

1.7 °C (JIS)

Cal. Date

03-07-2026

Temp. Element

Thermocouple Type E

Environment Condition