

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 0858-24-HI-CAL-10J

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0014-OTH

Instrument Information

KKS No.: 60HNA01AA201
 Instrument Description: AH INLET GAS DAMPER(RIGHT SIDE)(M1)
 Manufacture: AUMA
 Model: SA142-F14
 Serial Number: 2219MD24157
 Instrument Location: BOILER 5TH FLOOR
 Damping Time: 1 s
 Inspection Date: 22-05-2024

Environment Condition

Temperature: 32 °C
 Humidity: 43 % RH
 Traveling Time
 Open to Close: 40.27 s
 Close to Open: 49.13 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check: OK Not OK
 Corrosion Condition: OK Not OK
 Air Regulator Check: OK Not OK
 Tightness Check: OK Not OK
 Accessories Check: OK Not OK

Remark

Test Equipment

Description: STOPWATCH CASIO
 Serial Number: J011Q03
 Certificate Number: S. 23 004 599
 Calibration Date: 27-03-2023

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 23-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Taufiq Nur Fitriyan
 INDONESIA

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

