

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0467-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HNA01CP001	Range	-100 ~ 100
Instrument Description	ECONOMIZER A OUTLET GAS PRESSURE	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501775	Cal. Date	29-05-2024
Instrument Location	BOILER 7TH FLOOR		

### Environment Condition

Temperature: 27.6 °C  
 Humidity: 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100	4.000	4.002	0.002	0.012	Pass						
-50	8.000	8.004	0.004	0.025	Pass						
0	12.000	12.003	0.003	0.019	Pass						
50	16.000	16.003	0.003	0.019	Pass						
100	20.000	20.004	0.004	0.025	Pass						
100	20.000	20.004	0.004	0.025	Pass						
50	16.000	16.001	0.001	0.006	Pass						
0	12.000	12.006	0.006	0.038	Pass						
-50	8.000	7.992	-0.008	-0.050	Pass						
-100	4.000	3.993	-0.007	-0.044	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 30-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Alifidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person