

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0720-24-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60HNA01CT001  
 Instrument Description ECONOMIZER A OUTLET GAS TEMPERATURE 1 YAMARI  
 Manufacture -  
 Model -  
 Serial Number 5451673  
 Instrument Location BOILER 7TH FLOOR

Range 0 ~ 500  
 Unit °C  
 Out. Signal 4 - 20 mA  
 Max. Deviation 5 °C  
 Cal. Date 14-05-2024  
 Temp. Element Thermocouple Type E

### Environment Condition

Temperature 30.2 °C  
 Humidity 58 % RH

### Calibration Result

As Found					Data Reading				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	As Left Output UUT	Deviation	Result
40	40.000	40.200	0.200	Pass					
125	125.000	125.500	0.500	Pass					
250	250.000	250.900	0.900	Pass					
375	375.000	375.900	0.900	Pass					
500	500.000	501.200	1.200	Pass					

### Standard Reference

Description	Serial Number
Documenting Process Calibrator Fluke 754	43550006
Dry Block Calibrator Ametek	506481-00011

### Certificate Number

S. 22 022 080  
 S.24 - 00201

### Calibration Date

21-02-2022  
 27-02-2024

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 15-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory,



Khabib Mundzirul Umam

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

