

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0736-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60HNA01CT003

ECONOMIZER A OUTLET GAS TEMPERATURE 3

YAMARI

- / 5451675

BOILER 7TH FLOOR

Range

Unit

Out. Signal

Max. Deviation

Cal. Date

Temp. Element

0 ~ 500

°C

4-20 mA

5 °C

07-06-2026

Thermocouple Type E

Environment Condition

Temperature

25.0 °C

Humidity

58 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	39.600	25.100	-14.500	Fail					
125	126.000	29.300	-96.700	Fail					
250	251.600	29.300	-222.300	Fail					
375	376.200	29.300	-346.900	Fail					
500	501.800	29.300	-472.500	Fail					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



BROKEN

Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

DRY WELL CALIBRATOR ADDITEL
875

660TH19040016

S-25010822

22-08-2025

DOCUMENTING PROCESS
CALIBRATOR FLUKE 754

2448033

4482/25/EX/10/2025

26-09-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 24-06-2026

Customer Signature,

Erlan Nanda Gilfari

Approved Signatory,

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

