

CERTIFICATE OF CALIBRATION  
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0344-26-HI-CAL-10

## Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&amp;6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

## Instrument Information

KKS No.

60HNA03CP001

Instrument Description

AIR HEATER A OUTLET GAS PRESSURE

Manufacture

YOKOGAWA

Model / Serial Number

EJX130A / 91V501776

Instrument Location

BOILER 2ND FLOOR

Range

-100 ~ 100

Unit

mbar

Out. Signal

4 - 20 mA

Max. Error

0.5 %

Cal. Date

09-06-2026

## Environment Condition

Temperature

31 °C

Humidity

74 % RH

## Calibration Result

| Data Reading (Transmitter) |            |            |           |        |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |        |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [mbar]                     | [mA]       | [mA]       |           | [%]    |        | [mbar]  | [mA]       | [mA]       |           | [%]   |        |
| -100.000                   | 4.000      | 3.989      | -0.011    | -0.069 | Pass   |         |            |            |           |       |        |
| -50.000                    | 8.000      | 7.994      | -0.006    | -0.038 | Pass   |         |            |            |           |       |        |
| 0.000                      | 12.000     | 11.994     | -0.006    | -0.038 | Pass   |         |            |            |           |       |        |
| 50.000                     | 16.000     | 15.998     | -0.002    | -0.013 | Pass   |         |            |            |           |       |        |
| 100.000                    | 20.000     | 19.999     | -0.001    | -0.006 | Pass   |         |            |            |           |       |        |
| 50.000                     | 16.000     | 15.998     | -0.002    | -0.013 | Pass   |         |            |            |           |       |        |
| 0.000                      | 12.000     | 12.000     | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| -50.000                    | 8.000      | 7.994      | -0.006    | -0.038 | Pass   |         |            |            |           |       |        |
| -100.000                   | 4.000      | 3.990      | -0.010    | -0.063 | Pass   |         |            |            |           |       |        |

## Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



## Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

DOCUMENTING PROCESS CALIBRATOR FLUKE  
754

2448033

4482/25/EX/10/2025

26-09-2025

FLUKE PRESURE MODULE 750PD4

4474073

02171/GQI-Sert/03/26

09-03-2026

## Calibration Method

0001/SOP\_BJS/2025

Standard Operating Procedure of Calibration Pressure &amp; Differential Transmitter

This certificate comprises 2 pages

Date of issue, 11-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

  
HERVITAMA  
INDONESIA  
Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person