

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 0860-24-HI-CAL-10J

Customer Information

Company Name
Address
Contract No.

PT. Bhumi Jati Power
PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
C-BJP-24-0014-OTH

Instrument Information

KKS No.
Instrument Description
Manufacture
Model
Serial Number
Instrument Location

60HNA11AA201
AH INLET GAS DAMPER(LEFT SIDE)(M1)
AUMA
SA142-F14
2219MD24159
BOILER 5TH FLOOR

Damping Time 1 s
Inspection Date 22-05-2024

Environment Condition

Temperature 32 °C
Humidity 43 % RH

Traveling Time
Open to Close 49.06 s
Close to Open 49.10 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check
Corrosion Condition
Air Regulator Check

OK Not OK
 OK Not OK
 OK Not OK

Tightness Check OK Not OK
Accessories Check OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 23-05-2024

Customer Signature,



Ayrtun Humardani Putradhi

Applicant Signature,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Dayad Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

