

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0719-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HNA11CT003	Range	0 ~ 500
Instrument Description	ECONOMIZER B OUTLET GAS TEMPERATURE 3	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	5 °C
Serial Number	5451678	Cal. Date	14-05-2024
Instrument Location	BOILER 7TH FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 33 °C
 Humidity 47 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.900	-0.100	Pass					
125	125.010	125.500	0.490	Pass					
250	250.000	251.600	1.600	Pass					
375	375.000	376.500	1.500	Pass					
500	500.060	501.100	1.040	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 15-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,
HERVITAMA



M.INDONESIA ryan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

