

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0470-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60HNA13CP001 Range: -100 ~ 100
Instrument Description: AIR HEATER B OUTLET GAS PRESSURE Unit: mbarg
Manufacture: YOKOGAWA Out. Signal: 4 - 20 mA
Model: EJX130A Max. Error: 0.5 %
Serial Number: 91V501777 Cal. Date: 28-05-2024
Instrument Location: BOILER 2ND FLOOR

Environment Condition

Temperature: 27.2 °C
Humidity: 51 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100	4.000	4.001	0.001	0.006	Pass						
-50	8.000	8.000	0.000	0.000	Pass						
0	12.000	11.997	-0.003	-0.019	Pass						
50	16.000	15.999	-0.001	-0.006	Pass						
100	20.000	20.001	0.001	0.006	Pass						
100	20.000	20.001	0.001	0.006	Pass						
50	16.000	15.998	-0.002	-0.013	Pass						
0	12.000	11.996	-0.004	-0.025	Pass						
-50	8.000	7.996	-0.004	-0.025	Pass						
100	4.000	3.995	-0.005	-0.031	Pass						

Standard Reference


Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taqib Nur Fitriyan
INDONESIA

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

