

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0709-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HNA13CT001
 Instrument Description AIR HEATER B OUTLET GAS TEMPERATURE 1
 Manufacture YAMARI
 Model -
 Serial Number 5451626
 Instrument Location BOILER 3RD FLOOR

Range 0 ~ 200
 Unit °C
 Out. Signal 4 - 20 mA
 Max. Deviation 2 °C
 Cal. Date 13-05-2024
 Temp. Element Thermocouple Type E

Environment Condition

Temperature 30.2 °C
 Humidity 68 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.900	-0.100	Pass					
50	50.000	50.000	0.000	Pass					
100	100.010	100.900	0.890	Pass					
150	149.990	151.400	1.410	Pass					
200	200.000	201.200	1.200	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 14-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Lavinia Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

