

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0710-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HNA13CT002	Range	0 ~ 200
Instrument Description	AIR HEATER B OUTLET GAS TEMPERATURE 2	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	2 °C
Serial Number	5451627	Cal. Date	13-05-2024
Instrument Location	BOILER 3RD FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 31.6 °C
 Humidity 57 % RH

Calibration Result

Data Reading				
As Found			As Left	
Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]		
40	40.000	40.100	0.100	Pass
50	50.000	50.200	0.200	Pass
100	100.010	101.000	0.990	Pass
150	150.010	151.300	1.290	Pass
200	200.030	201.700	1.670	Pass

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 14-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Tjoto Nurfitriyan

Calibrated by,



Khabil Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

***Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang**

This certificate is valid if it has approved and signed by authorized person

