

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0706-24-HI-CAL-10D

### Customer Information

Company Name PT. Bumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HNA15CT002	Range	0 ~ 200
Instrument Description	IDF B INLET GAS TEMP 2	Unit	°C
Manufacture	YAMARI	Out. Signal	4-20 mA
Model	-	Max. Deviation	2 °C
Serial Number	5451634	Cal. Date	12-05-2024
Instrument Location	BOILER / ID FAN B	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 32.5 °C  
 Humidity 71 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.300	0.300	Pass					
50	50.000	50.300	0.300	Pass					
100	100.000	100.500	0.500	Pass					
150	150.000	150.500	0.500	Pass					
200	200.000	200.000	0.000	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 13-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Teguh Nur Priyana

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

