CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0354-26-HI-CAL-10

Customer Information

Company Name	PT. Bhumi Jati Power
Address	PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.	C-BJP-26-0004-OTH

Instrument Information

KKS No.	60HNC01CF002	Range	0 ~ 49.2
Instrument Description	INDUCED DRAFT FAN A SUCTION GAS FLOW 2	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model / Serial Number	EJX430A / 91V501680	Max. Error	0.5 %
Instrument Location	BOILER 3RD FLOOR	Cal. Date	08-06-2026

Environment Condition

Temperature	26 °C	Humidity	55 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input [mbar]	Std Output [mA]	Output UUT [mA]	Deviation	Error [%]	Result	Input [mbar]	Std Output [mA]	Output UUT [mA]	Deviation	Error [%]	Result
0.000	4.000	4.001	0.001	0.006	Pass						
12.300	8.000	8.000	0.000	0.000	Pass						
24.600	12.000	12.000	0.000	0.000	Pass						
36.900	16.000	16.001	0.001	0.006	Pass						
49.200	20.000	20.000	0.000	0.000	Pass						
36.900	16.000	16.000	0.000	0.000	Pass						
24.600	12.000	12.001	0.001	0.006	Pass						
12.300	8.000	8.001	0.001	0.006	Pass						
0.000	4.000	4.001	0.001	0.006	Pass						

Visual Inspection (Checklist if OK)

Leak Check	☑	Tightness Check	☑	Corrosion Check	☑
Accessories Check	☑	Power Supply	☑		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 700P05	14270508	02837/GQI-Sert/04/26	13-04-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 11-06-2026

Customer Signature,	Approved Signatory,	Calibrated by,
Erfan Nanda Gifari	Ivan Hasan Ashari	Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*
This certificate is valid if it has approved and signed by authorized person