

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0290-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60HNC01CP002  
 Instrument Description INDUCED DRAFT FAN A CONTROL OIL PRESSURE 2  
 Manufacture YOKOGAWA  
 Model EJX430A  
 Serial Number 91V501782  
 Instrument Location BOILER ID FAN

Range 0 ~ 100  
 Unit barg  
 Out. Signal 4 - 20 mA  
 Max. Error 0.5 %  
 Cal. Date 18-05-2024

### Environment Condition

Temperature 31.7 °C  
 Humidity 66 % RH

### Calibration Result

| As Found |            |            |           |        |        | As Left |            |            |           |       |        |
|----------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| Input    | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [barg]   | [mA]       | [mA]       |           | [%]    |        | [barg]  | [mA]       | [mA]       |           | [%]   |        |
| 0.00     | 4.000      | 4.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 25.03    | 8.005      | 8.000      | -0.005    | -0.031 | Pass   |         |            |            |           |       |        |
| 50.06    | 12.009     | 11.998     | -0.011    | -0.069 | Pass   |         |            |            |           |       |        |
| 75.01    | 16.002     | 16.017     | 0.015     | 0.094  | Pass   |         |            |            |           |       |        |
| 100.04   | 20.006     | 20.001     | -0.005    | -0.031 | Pass   |         |            |            |           |       |        |
| 100.04   | 20.006     | 20.001     | -0.005    | -0.031 | Pass   |         |            |            |           |       |        |
| 75.01    | 16.002     | 15.997     | -0.005    | -0.031 | Pass   |         |            |            |           |       |        |
| 50.06    | 12.009     | 12.002     | -0.007    | -0.044 | Pass   |         |            |            |           |       |        |
| 25.03    | 8.005      | 7.999      | -0.006    | -0.038 | Pass   |         |            |            |           |       |        |
| 0.00     | 4.000      | 4.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 3611011       | S. 22 011 747      | 23-09-2023       |
| PRESSURE MODULE P31                      | 4472839       | S. 23 004 595      | 27-03-2023       |

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 19-05-2024

Customer Signature,




Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

