

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0356-26-HI-CAL-10

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

### Instrument Information

KKS No. 60HNC01CP002  
Instrument Description INDUCED DRAFT FAN A CONTROL OIL PRESSURE 2  
Manufacture YOKOGAWA  
Model / Serial Number EJX430A / 91V501782  
Instrument Location BOILER ID FAN

Range 0 ~ 100  
Unit bar  
Out. Signal 4 - 20 mA  
Max. Error 0.5 %  
Cal. Date 07-06-2026

### Environment Condition

Temperature 30.7 °C Humidity 55 % RH

### Calibration Result

| Data Reading (Transmitter) |            |            |           |       |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|-------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |       |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [bar]                      | [mA]       | [mA]       |           | [%]   |        | [bar]   | [mA]       | [mA]       |           | [%]   |        |
| 0.000                      | 4.000      | 4.002      | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 25.030                     | 8.004      | 8.004      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 50.060                     | 12.009     | 12.010     | 0.001     | 0.006 | Pass   |         |            |            |           |       |        |
| 75.010                     | 16.001     | 16.003     | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 100.040                    | 20.006     | 20.010     | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| 75.010                     | 16.001     | 16.001     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 50.060                     | 12.009     | 12.009     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 25.030                     | 8.004      | 8.004      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 0.000                      | 4.000      | 4.000      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |

### Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|------------------------------------------|---------------|--------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 56070038      | MAL 26031230       | 06-03-2026       |
| FLUKE PRESEURE MODULE 750P31             | 4472839       | MAL 26031236       | 03-03-2026       |

### Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 10-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved Signatory,



Ivan Hasan Asnari

Calibrated by,



Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person