

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0291-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HNC01CP003	Range	0 ~ 100
Instrument Description	INDUCED DRAFT FAN A CONTROL OIL PRESSURE 3	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501783	Cal. Date	18-05-2024
Instrument Location	BOILER ID FAN		

Environment Condition

Temperature 31.7 °C
 Humidity 66 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
25.03	8.005	7.998	-0.007	-0.044	Pass						
50.06	12.009	12.006	-0.003	-0.019	Pass						
75.01	16.002	15.999	-0.003	-0.019	Pass						
100.04	20.006	20.004	-0.002	-0.012	Pass						
100.04	20.006	20.004	-0.002	-0.012	Pass						
75.01	16.002	16.008	0.006	0.038	Pass						
50.06	12.009	12.012	0.003	0.019	Pass						
25.03	8.005	7.996	-0.009	-0.056	Pass						
0.00	4.000	4.000	0.000	0.000	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 19-05-2024

Customer Signature,




Ayrton Humardani Putradhi

HERVITAMA
 Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person