

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0293-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HNC01CP005	Range	200 ~ 2000
Instrument Description	INDUCED DRAFT FAN A LUBE OIL PRESSURE 2	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0,5 %
Serial Number	91V501785	Cal. Date	17-05-2024
Instrument Location	BOILER 1ST FLOOR		

### Environment Condition

Temperature 29.2 °C  
 Humidity 52 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
200	4.000	3.994	-0.006	-0.037	Pass						
650	8.000	7.993	-0.007	-0.044	Pass						
1100	12.000	11.993	-0.007	-0.044	Pass						
1550	16.000	15.994	-0.006	-0.038	Pass						
2000	20.000	19.998	-0.002	-0.012	Pass						
2000	20.000	19.998	-0.002	-0.012	Pass						
1550	16.001	15.995	-0.006	-0.038	Pass						
1100	12.001	11.997	-0.004	-0.025	Pass						
650	8.000	7.996	-0.004	-0.025	Pass						
200	3.999	3.994	-0.005	-0.031	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 18-05-2024

Customer Signature,




Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,



M. Turfina Nur Fitriyan

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

