

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0294-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HNC01CP006	Range	200 ~ 2000
Instrument Description	INDUCED DRAFT FAN A LUBE OIL PRESSURE 3	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501786	Cal. Date	17-05-2024
Instrument Location	BOILER 1ST FLOOR		

Environment Condition

Temperature 29.1 °C
 Humidity 53 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
200	4.000	3.993	-0.007	-0.044	Pass						
650	8.000	7.997	-0.003	-0.019	Pass						
1100	12.000	11.996	-0.004	-0.025	Pass						
1550	16.000	15.997	-0.003	-0.019	Pass						
2000	20.000	19.994	-0.006	-0.038	Pass						
2000	20.000	19.994	-0.006	-0.038	Pass						
1550	16.000	15.994	-0.006	-0.038	Pass						
1100	12.000	11.997	-0.003	-0.019	Pass						
650	8.000	7.998	-0.002	-0.012	Pass						
200	4.000	3.993	-0.007	-0.044	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 18-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA
 Approved Signatory,



M. Idris Nur Fitriyan

Calibrated by,



Faihsol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

