

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0295-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60HNC01CP007 Range: 0 ~ 100
 Instrument Description: INDUCED DRAFT FAN A SEAL AIR PRESSURE 1 Unit: mbarg
 Manufacture: YOKOGAWA Out. Signal: 4 - 20 mA
 Model: EJX430A Max. Error: 0.5 %
 Serial Number: 91V501802 Cal. Date: 17-05-2024
 Instrument Location: BOILER 1ST FLOOR

Environment Condition

Temperature: 29.2 °C
 Humidity: 52 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
0	4.000	4.009	0.009	0.056	Pass						
25	8.000	8.004	0.004	0.025	Pass						
50	12.000	12.007	0.007	0.044	Pass						
75	16.016	16.025	0.009	0.056	Pass						
100	20.000	20.005	0.005	0.031	Pass						
100	20.000	20.005	0.005	0.031	Pass						
75	16.000	16.014	0.014	0.087	Pass						
50	12.000	12.006	0.006	0.038	Pass						
25	8.000	7.999	-0.001	-0.006	Pass						
0	4.000	4.003	0.003	0.019	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page

Date of issue, 18-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA
 Approved Signatory,



M. Tawfik Nur Fitriyan
 INDONESIA

Calibrated by



Faisol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

