

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0362-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HNC01CP008
Instrument Description INDUCED DRAFT FAN A SEAL AIR PRESSURE 2
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V501803
Instrument Location BOILER 1ST FLOOR

Range 0 ~ 100
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 08-06-2026

Environment Condition

Temperature 31 °C Humidity 74 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	4.005	0.005	0.031	Pass						
25.000	8.000	8.004	0.004	0.025	Pass						
50.000	12.000	12.002	0.002	0.013	Pass						
75.000	16.000	16.002	0.002	0.013	Pass						
100.000	20.000	20.003	0.003	0.019	Pass						
75.000	16.000	16.002	0.002	0.013	Pass						
50.000	12.000	12.002	0.002	0.013	Pass						
25.000	8.000	8.002	0.002	0.013	Pass						
0.000	4.000	4.004	0.004	0.025	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 700P05	14270508	02837/GQI-Sert/04/26	13-04-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 11-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved by,

HERVITAMA
INDONESIA
Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

