

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0755-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60HNC01CT002	Range	0 ~ 150
Instrument Description	INDUCED DRAFT FAN A RADIAL BEARING TEMPERATURE NO.2 HIGH	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model / Serial Number	- / -	Max. Deviation	1.7 °C (JIS)
Instrument Location	ID FAN A	Cal. Date	10-06-2026
		Temp. Element	Thermocouple Type E

Environment Condition

Temperature 28.7 °C Humidity 69 % RH

Calibration Result

As Found					Data Reading					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.900	0.300	Pass										
60	59.600	60.300	0.700	Pass										
90	89.900	90.600	0.700	Pass										
120	119.700	121.000	1.300	Pass										
150	150.200	151.000	0.800	Pass										

Visual Inspection (Checklist if OK)

Leak Check ☐	Tightness Check ☒	Corrosion Check ☒
Accessories Check ☒	Power Supply ☐	

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS	3611011	MAL 26031229	06-03-2026
CALIBRATOR FLUKE 754			
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025
Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 14-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved by,



Ivan Hasan Ashari

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person