

CERTIFICATE OF CALIBRATION  
TEMPERATURE SENSOR

Certificate No. : 0757-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60HNC01CT004 Range 0 ~ 150  
Instrument Description INDUCED DRAFT FAN A THRUST BEARING TEMPERATURE HIGH (NON- MOTOR SIDE) Unit °C  
Manufacture YAMARI Out. Signal 4 - 20 mA  
Model / Serial Number - / - Max. Deviation 1.7 °C (JIS)  
Instrument Location ID FAN A Cal. Date 10-06-2026  
Temp. Element Thermocouple Type E

## Environment Condition

Temperature 28.7 °C Humidity 68 % RH

## Calibration Result

| As Found |            |            |           |        | As Left |            |            |           |        |
|----------|------------|------------|-----------|--------|---------|------------|------------|-----------|--------|
| Input    | Std Output | Output UUT | Deviation | Result | Input   | Std Output | Output UUT | Deviation | Result |
| [°C]     | [°C]       | [°C]       |           |        | [°C]    | [°C]       | [°C]       |           |        |
| 40       | 39.600     | 39.900     | 0.300     | Pass   |         |            |            |           |        |
| 60       | 59.600     | 60.100     | 0.500     | Pass   |         |            |            |           |        |
| 90       | 89.900     | 90.500     | 0.600     | Pass   |         |            |            |           |        |
| 120      | 119.700    | 120.600    | 0.900     | Pass   |         |            |            |           |        |
| 150      | 150.200    | 150.900    | 0.700     | Pass   |         |            |            |           |        |

## Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☐

## Standard Reference

| Description                                 | Serial Number | Certificate Number | Calibration Date |
|---------------------------------------------|---------------|--------------------|------------------|
| DOCUMENTING PROCESS<br>CALIBRATOR FLUKE 754 | 3611011       | MAL 26031229       | 06-03-2026       |
| DRY WELL CALIBRATOR ADDITEL<br>875          | 660TH19040016 | S-25010822         | 22-08-2025       |

## Calibration Method

0002/SOP\_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter &amp; Temperature Switch

This certificate comprises 2 pages

Date of issue, 14-06-2026

Customer Signature,

Erfan Nanda Gifari

Authorized by,

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

