

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0300-24-HI-CAL-10C

### Customer Information

Company Name PT. Bumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60HNC11CP002 Range 0 ~ 100  
 Instrument Description INDUCED DRAFT FAN B CONTROL OIL PRESSURE 2 Unit barg  
 Manufacture YOKOGAWA Out. Signal 4 - 20 mA  
 Model EJX430A Max. Error 0.5 %  
 Serial Number 91V5011791 Cal. Date 18-05-2024  
 Instrument Location BOILER ID FAN

### Environment Condition

Temperature 31.7 °C  
 Humidity 66 % RH

### Calibration Result

#### Data Reading (Transmitter)

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
25.03	8.005	8.009	0.004	0.025	Pass						
50.06	12.009	12.014	0.005	0.031	Pass						
75.01	16.002	16.003	0.001	0.006	Pass						
100.04	20.006	19.992	-0.014	-0.087	Pass						
100.04	20.006	19.992	-0.014	-0.087	Pass						
75.01	16.002	16.000	-0.002	-0.012	Pass						
50.06	12.009	11.993	-0.016	-0.100	Pass						
25.03	8.005	7.998	-0.007	-0.044	Pass						
0.00	4.000	3.998	-0.002	-0.012	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Callibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 19-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

