

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0369-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HNC11CP005 Range 200 ~ 2000
Instrument Description INDUCED DRAFT FAN B LUBE OIL PRESSURE 2 Unit mbar
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX430A / 91V501793 Max. Error 0.5 %
Instrument Location BOILER 1ST FLOOR Cal. Date 08-06-2026

Environment Condition

Temperature 31 °C Humidity 74 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
200.000	4.000	4.000	0.000	0.000	Pass						
650.000	8.000	8.004	0.004	0.025	Pass						
1100.000	12.000	12.004	0.004	0.025	Pass						
1550.000	16.000	16.004	0.004	0.025	Pass						
2000.000	20.000	20.005	0.005	0.031	Pass						
1550.000	16.000	16.004	0.004	0.025	Pass						
1100.000	12.000	12.004	0.004	0.025	Pass						
650.000	8.000	8.005	0.005	0.031	Pass						
200.000	4.000	4.001	0.001	0.006	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 700P05	14270508	02837/GQI-Sert/04/26	13-04-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 11-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signature

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person